



Science Arts & Métiers (SAM)

is an open access repository that collects the work of Arts et Métiers Institute of Technology researchers and makes it freely available over the web where possible.

This is an author-deposited version published in: <https://sam.ensam.eu>
Handle ID: [.http://hdl.handle.net/10985/14717](http://hdl.handle.net/10985/14717)

To cite this version :

Taoufik QORIA, Philippe DELARUE, Frédéric COLAS, Xavier GUILLAUD, Philippe LE MOIGNE - Modeling and Control of the Modular Multilevel Converter connected to an inductive DC source using Energetic Macroscopic Representation - In: EPE, Lettonie, 2018-09 - n/a - 2018

Any correspondence concerning this service should be sent to the repository

Administrator : scienceouverte@ensam.eu



Modeling and Control of the Modular Multilevel Converter connected to an inductive DC source using Energetic Macroscopic Representation

T.QORIA, F.GRUSON, P.DELARUE, P.LE MOIGNE, F.COLAS, X.GUILLAUD

Univ. Lille, Arts et Metiers ParisTech, Centrale Lille, HEI, EA 2697-L2EP-Laboratoire d'Electrotechnique et d'Electronique de Puissance,
F-59000 Lille, France
E-Mail: taoufik.qoria@ensam.eu

Acknowledgements

The results presented in this paper are part of ESPESA project that has received funding from the European Union's Horizon 2020 research and innovation program under grant agreement No 692224.



Keywords

« Modular Multilevel Converter (MMC) », «DC side inductor», «High Voltage Direct Current (HVDC) », «Power transmission».

Abstract

The use of DC transmission is particularly advantageous for long-distance transmission and interconnection of asynchronous AC networks. Several converter topologies can be used for HVDC. Multilevel Modular Converters (MMCs) are the most favored given their technological advantages over other converters topologies. Due to their industrial maturity, they have become essential for all AC / DC conversion. So far, they have always been studied with a voltage source on DC side. However, when the converter is equipped with DC breaker, a series inductor is associated to limit current variations. This has consequences in term of modeling and control determination. This article aims to propose a modification of the control law in order to take into account this inductor. To facilitate the control organization, the Energetic Macroscopic Representation (EMR) is used.

Introduction

The debate over AC or DC electric power transmission systems dates back to the late 19th century with the dispute between Thomas Edison's DC system and Westinghouse's AC technology. As a result, AC transmission systems became the predominant technology adopted. It was not until the 1930s, when the mercury arc valve was invented that the development of high voltage direct current (HVDC) transmission systems started [1]. In 1941, the first contract for a commercial HVDC system was placed and since then it became an alternative to AC transmission

HVDC technology is also the best solution to meet the demand for long-distance power transmission technologies thanks to their technical and economic advantages [2]. The first conversion technologies for HVDC applications were based on current source converters (CSCs) using thyristors. The introduction of power semiconductors with open/close capabilities has made possible the development of voltage source converters (VSCs). Recently, the modular multilevel converter (MMC) shown in Figure.1 has been quickly seen in a wide variety of applications as a result of significant advantages over previous technologies while retaining the properties of a conventional VSC.

With a sufficient number of levels, the output filter can be eliminated. In addition, since the switching frequency is lower for this converter, losses are reduced [3]. For the reasons stated, the MMC is a very interesting topology, not only for HVDC transmission, but also for other applications such as variable

speed drives, STATCOM, wind power generation. MMC technology has been widely accepted in the industry as it achieves high levels of power (1GW) and voltage (640kV).




Fig.1: Modular Multilevel Converter structure

In a point-to-point HVDC link, a DC fault results in the interruption of the link by opening the AC circuit breakers. In case of MTDC network, it is necessary to isolate the faulty link using DC breaker circuit which remains a major challenge until now. Thanks to the rapid progress of the technology, it is possible now to cut a direct current in a specific point of the network with the devices "Direct Current Circuit Breaker (DCCB) [4]". These latter are usually put in series with inductors of large values. It is possible, in this case, to represent the DC side of the converter by a voltage source in series with an inductor as shown in Figure 2. The purpose of this paper is not particularly concerned with faults, but it is focused on the impact of this inductor on the operation of the system and its consideration on the control law. It is also possible to generalize this study to an inductor coming from a DC transmission line [5].




Fig.2: Simplified diagram of the MMC connected to an inductive DC source.

The conventional control strategies developed for an MMC connected to a DC voltage source [6-10] are no longer valid in the case of a strong inductor present on the DC bus, since this latter strongly influences the stability of the system as the shows the simulation below (Fig.3).




Fig.3: Conventional controls impact on the system stability

As it can be seen, the stability is no longer ensured in the case of a negative power flow. For this reason, it is important and necessary to have a suitable model of the MMC to integrate the impact of this inductor and subsequently to develop a suitable control law.

Most of the authors model the DC bus as a voltage source [6-10], the first work close to our problematic was done by [11] relying on several considerations and hypotheses at the modeling level. This latter considers that the DC power is equitably distributed in the three legs. This hypothesis is true in the case where the system is symmetrical with a perfect balanced network. But in case of a converter with many components (like the MMC), the symmetry of the system cannot be ensured (ex: losses in arms). Moreover, the balance of the network is not guaranteed [12].

The objective of this paper is to propose a new control law to keep the system stable for a high inductor value as the one considered in [4].

System modeling

Average model of the Modular Multilevel Converter

Given the large number of submodules (SMs), the study is based on the average model of the MMC considering that the capacitor voltages are well balanced [9]. Therefore, each arm is represented by an ideal DC / DC converter controlled by a modulation ratio defined as the ratio of the active submodule number divided by the total number of submodules, an equivalent capacitor of value C/N , and an equivalent voltage $v_{c_{tot}} = v_1 + v_2 + v_3 \dots \dots + v_n$.




Fig. 4. Average model of the MMC-arm [9]

The modulated voltage and current of each arm v_m, i_m are respectively expressed as follow:

$$v_m = m \cdot v_{c_{tot}} \quad (1)$$

$$i_m = m \cdot v_m \quad (2)$$

We can therefore deduce the evolution of the modulated current by the following equation:

$$i_m = C_{tot} \cdot \frac{d}{dt}(v_{c_{tot}}) \quad (3)$$

System equation

According to Kirchhoff's law, two equations are obtained from the inner loop of the MMC allowing a first modeling ($x = a, b, c$):

$$\frac{\bar{V}_{dc}}{2} - \frac{L_{dc}}{2} \cdot \frac{d\vec{i}_{dc}}{dt} - \frac{R_{dc}}{2} \cdot \vec{i}_{dc} - \vec{v}_{m_{ux}} - L_a \cdot \frac{d\vec{i}_{m_{ux}}}{dt} - R_a \cdot \vec{i}_{m_{ux}} = \vec{v}_{g_x} + L \cdot \frac{d\vec{i}_{g_x}}{dt} + R \cdot \vec{i}_{g_x} - \vec{v}_{n0} \quad (4)$$

$$-\frac{\bar{V}_{dc}}{2} + \frac{L_{dc}}{2} \cdot \frac{d\vec{i}_{dc}}{dt} + \frac{R_{dc}}{2} \cdot \vec{i}_{dc} + \vec{v}_{m_{lx}} + L_a \cdot \frac{d\vec{i}_{m_{lx}}}{dt} + R_a \cdot \vec{i}_{m_{lx}} = \vec{v}_{g_x} + L \cdot \frac{d\vec{i}_{g_x}}{dt} + R \cdot \vec{i}_{g_x} - \vec{v}_{n0} \quad (5)$$

The modeling of the AC side is done by the summation of the equations (4) and (5):

$$v_{m_{lx}} - v_{m_{ux}} + L_a \frac{d}{dt}(i_{m_{lx}} - i_{m_{ux}}) + R_a (i_{m_{lx}} - i_{m_{ux}}) = 2(v_{g_x} + L_g \frac{d}{dt}(i_{g_x}) + R_g \frac{d}{dt}(i_{g_x})) \quad (6)$$

Considering the variable change as in [13], with $i_{u_x} = i_{g_x} + i_{l_x}$:

$$v_{v_x} = \frac{v_{m_{lx}} - v_{m_{ux}}}{2} \quad (7)$$

$$v_{diff_x} = \frac{v_{m_{lx}} + v_{m_{ux}}}{2} \quad (8)$$

$$i_{diff_x} = \frac{i_{l_x} + i_{m_x}}{2} \quad (9)$$

The fusion of equations (6) and (7) defines the equations vector of the state variables i_{g_x} :

$$v_{v_x} - v_{g_x} = \left(\frac{L_a}{2} + L_g\right) \frac{d}{dt}(i_{g_x}) + \left(\frac{R_a}{2} + R_g\right) (i_{g_x}) \quad (10)$$

Conventionally, the line currents are controlled in Park domain.

In a similar way to the modeling of the AC side, the integration of (8) and (9) in the difference of the equations (4) and (5) allows the modeling of the DC bus:

$$\frac{V_{dc}}{2} - v_{diff_x} = \frac{L_{dc}}{2} \cdot \frac{d}{dt}(i_{dc}) + \frac{R_{dc}}{2} (i_{dc}) + L_a \cdot \frac{d}{dt}(i_{diff_x}) + R_a (i_{diff_x}) \quad (11)$$

It is clear that the equation (11) contains coupled state variables since $i_{dc} = i_{diff_a} + i_{diff_b} + i_{diff_c}$. This coupling is due to the presence of the inductor on the DC side. As a result, the differential i_{diff_x} can no longer be controlled independently as in the case of an MMC connected to a DC voltage source. One solution consists in defining another model, compared to the one usually used for the MMC, by defining a new variable change allowing the decoupling of the system variables.

$$\frac{d}{dt} \begin{bmatrix} i_{diffa} \\ i_{diffb} \\ i_{diffc} \end{bmatrix} = - \underbrace{\begin{bmatrix} \frac{L_{dc}}{2} + L_a & L_a & L_a \\ L_a & \frac{L_{dc}}{2} + L_a & L_a \\ L_a & L_a & \frac{L_{dc}}{2} + L_a \end{bmatrix}^{-1}}_B \underbrace{\begin{bmatrix} \frac{R_{dc}}{2} + R_a & R_a & R_a \\ R_a & \frac{R_{dc}}{2} + R_a & R_a \\ R_a & R_a & \frac{R_{dc}}{2} + R_a \end{bmatrix}^{-1}}_A \begin{bmatrix} i_{diffa} \\ i_{diffb} \\ i_{diffc} \end{bmatrix} + \begin{bmatrix} \frac{v_{dc}}{2} - v_{diffa} \\ \frac{v_{dc}}{2} - v_{diffb} \\ \frac{v_{dc}}{2} - v_{diffc} \end{bmatrix} \quad (12)$$

The matrix can be decomposed into left eigenvectors matrix denoted P , right eigenvectors matrix denoted P^{-1} and a diagonal matrix of eigenvalues D such as $A = PDP^{-1}$.

The multiplication of the equation (12) by the matrix P^{-1} on both sides allows to obtain the following expression:

$$P^{-1} \frac{d}{dt} (i_{diffx}) = DP^{-1} i_{diffx} + P^{-1} B \left(\frac{V_{dc}}{2} - v_{diffx} \right) \quad (13)$$

From this equation, a new variable change is defined:

$$i_{diffnx} = P^{-1} i_{diffx} \quad (14)$$

$$\frac{d}{dt} (i_{diffnx}) = D \cdot i_{diffnx} + T \left(\frac{V_{dc}}{2} - v_{diffx} \right) \quad (15)$$

Where: $T = P^{-1}B$, $V_{acn} = TV_{dc}$, $v_{diffn} = Tv_{diff}$.

Depending on this development, the combination of accumulation elements is now possible. Therefore the whole system is presented by 11 differential equations (11 state variables, 5 currents and 6 voltages). These equations are completely decoupled.

From the equations developed above, the MMC is presented using EMR tool [14] as shown in Fig.5:




Fig. 5. EMR of the Modular Multilevel Converter

System control

Inner loop control

The 11 state variables are controlled from 6 control inputs $m_{u/l}$ similarly for an MMC connected to a DC voltage source. The goal of the control is to obtain balanced sinusoidal currents on the AC side of amplitude such P_{ref} , Q_{ref} and a continuous current in steady state on DC side. These objectives are

achieved by controlling the new differential currents i_{diffn} and line currents i_{gx} . The controllers used are the PI (Proportional Integral), it is also possible to use PR controllers (Proportional Resonant) [15]. The inner control law is deduced through a direct inversion of the model (Fig.6).




Fig. 6. Inner loop control structure

To avoid possible instability issues due to non-control of capacitor voltages v_{ctot} , an energy-based control strategy is developed in order to obtain a maximum control structure.

Energy based control

The energy based control strategy relies mainly on the power conservation law in each arm:

$$\langle P_u \rangle = \langle v_{mu_x} \cdot i_{u_x} \rangle = \langle v_{m_x} \cdot i_{mu_x} \rangle \quad (16)$$

$$\langle P_l \rangle = \langle v_{ml_x} \cdot i_{l_x} \rangle = \langle v_{l_x} \cdot i_{ml_x} \rangle \quad (17)$$

Knowing that: $\langle P \rangle = \langle \frac{d}{dt} W \rangle = \frac{c_{tot}}{2} \frac{d}{dt} (v_{ctot}^2)$

The integration of the variable change (7) (8) and (9) in the equations (16) and (17) allows a first average energy modeling of arms:

$$\langle \frac{d}{dt} W_{u_x} \rangle = \langle (v_{diff_x} - v_{v_x}) \left(i_{diff_x} + \frac{1}{2} i_{g_x} \right) \rangle \quad (18)$$

$$\langle \frac{d}{dt} W_{l_x} \rangle = \langle (v_{diff_x} + v_{v_x}) \left(i_{diff_x} - \frac{1}{2} i_{g_x} \right) \rangle \quad (19)$$

The sum " Σ " and the difference " Δ " of (18) and (19):

$$\frac{d}{dt} W_x^\Sigma = \langle 2v_{diff_x} \cdot i_{diff_x} - v_{v_x} \cdot i_{g_x} \rangle \quad (20)$$

$$\frac{d}{dt} W_x^\Delta = \langle v_{diff_x} \cdot i_{g_x} - 2v_{v_x} \cdot i_{diff_x} \rangle \quad (21)$$

The differential current is defined as the sum of a DC component and an AC component:

$$i_{diff_x} = i_{diff_xAC} + i_{diff_xDC} \quad (22)$$

We do the same for the new defined variables:

$$i_{diff_{xn}} = i_{diff_{xnAC}} + i_{diff_{xnDC}} \quad (23)$$

Where $\langle i_{diff_{xAC}} \rangle = 0$ and $\langle i_{diff_{xnAC}} \rangle = 0$.

In steady state $v_{diff_x} \approx \frac{V_{dc}}{2}$, and $v_v \approx v_g$. These considerations lead to two equations allowing the control of the fictitious AC differential currents through the control of the energy difference W_x^Δ between upper and the lower arms, and the control of the fictitious DC differential currents through the control of the energy sum W_x^Σ :

$$\frac{d}{dt} W_x^\Sigma = \langle V_{dc} \cdot i_{diff_{xnDC}} \cdot P - v_{gx} \cdot i_{gx} \rangle \quad (24)$$

$$\frac{d}{dt} W_x^\Delta = \langle -2v_{gx} \cdot i_{gx} - 2v_{gx} \cdot i_{diff_{xnAC}} \cdot P \rangle \quad (25)$$

Unlike conventional controls where the energy of the arms is controlled individually, the presence of a strong inductor in the DC side creates an energy coupling between the arms of the MMC.

It is remarkable from equation (24) that the total energy stored in each arm depends mainly on the power exchange between the power p_{ac} , which depends on the direct component i_{gd} , and the power p_{dc} which depends on the DC component of the differential current.

Only the average value of the AC power will be taken into account in the energy model, therefore, the fluctuating power is neglected. The compensation by the instantaneous AC power introduces an undesired AC component into the differential currents, even if it reduces the ripple across the equivalent capacitor voltages [9].

The reference of line currents is defined from the measurement of the grid voltage and the active/reactive power of reference.

The control law of the energy based model (eq.24 and 25) is obtained by a direct model inversion:




Fig. 7. Maximal control structure of the Modular Multilevel Converter

Simulation and results

To validate the proposed control law, the simulations were performed on Matlab/Simulink.

The parameters used are indicated on Tab.1. These latter come from the HVDC INELF link [16], and the inductor value used on the DC side comes from the reference [4].

Only the variables at the input and at the output of the converter are presented in Fig. 8. At first, the power set point is initialized to zero until $t = 0.2s$, then $P = 1GW$ is imposed until $t = 0.6s$, then $-1GW$ until $t = 1s$.

Table I. System parameters

P_n	1 GW	R_a	50 mH
V_{res}	192 kV	L_a	50 mH
f_{res}	50 Hz	R_{dc}	300 mΩ
V_{dc}	640 kV	L_{dc}	300 mH
R	60 mH	C_{tot}	25 μF
L	60 mH		

It is remarkable that DC and AC powers follow the reference with a negligible difference due to Joule losses (the switches are supposed perfect). The line currents are sinusoidal and well balanced, and the DC side current side is continuous in steady state for each power set point. The system remains stable even with high L_{dc} value which was not the case for the control of the MMC connected to a voltage source (Fig.3).




Fig. 8. Input and output variables of the converter

Figure 9 shows internal variables of the converter. It can be seen that the arms currents consist of a DC component and an AC component, the sum of the differential currents is equal to the DC current and the average values of the differential currents are almost equal, which means that the power is evenly distributed on the converter arms. The voltages across the capacitors are centered on their 640kV reference value.

The initial results of the simulation show that the system is stable since all state variables are well controlled.










Fig. 9. Internal variables of the converter

Conclusion

The first part of this paper allowed detailing the structure of the Modular Multilevel Converter, poses the issue related to the presence of an inductor in its DC bus, explains its operating principle, and its mathematical model. This part showed at first, the coupling of the system states due to the presence of the inductive node, thus, a methodology to solve this problem was proposed. The second part dealt with the converter control (line currents, the differential currents and the energy stored in the equivalent capacitors). Unlike other control strategies, all state variables have been controlled to avoid system instability. This ensures a good dynamic behavior and increases the system robustness.

Appendix

ENERGETIC MACROSCOPIC REPRESENTATION (EMR) [14]			
EMR is a systemic extension of COG, based on the interaction principle.			
	Action and reaction variables		Energy source (system terminals)

	Energy accumulation (energy storage)		indirect inversion (closed-loop control)
	Mono-physical converter (energy conversion)		direct inversion (open-loop control)
	Strategy (energy management)		direct inversion using a disturbance rejection

References

- [1] C.-K. Kim, V. K. Sood, G.-S. Jang, S.-J. Lim, and S.-J. Lee, *Development of HVDC Technology*, ch. 1, pp. 1–35. John Wiley Sons, Ltd, 2010.
- [2] P. Rault, *Dynamic Modeling and Control of Multi-terminal HVDC grids*. PhD thesis, Ecole Centrale de Lille, Lille, France, 2014. T. Lubin, K. Berger, et A. Rezzoug, « Inductance and Force Calculation for Axisymmetric Coil Systems Including an Iron Core of Finite Length », *Progress In Electromagnetics Research B*, vol. 41, p. 377-396, juin 2012.
- [3] B. R. Andersen, L. Xu, and K. T. G. Wong, “Topologies for VSC transmission,” in *AC-DC Power Transmission*, 2001. Seventh International Conference on (Conf. Publ. No.485), 2001, pp. 298–304.
- [4] K. Tahata et al., “HVDC circuit breakers for HVDC grid applications,” *AC and DC power transmission*, 11th IET International Conference on, BBrūingham, 2015, pp.19. doi: 10.1049/cp.2015.0018
- [5] <https://www.energy.siemens.com/hq/en/power-transmission/hvdc/references.htm#ultranet-germany/projects>
- [6] F. Martinez-Rodrigo, S. de Pablo, and L. C. Herrero-de Lucas, “Current control of a modular multilevel converter for HVDC applications,” *Renewable Energy*, vol. 83, pp.318–331, Nov. 2015.
- [7] J. Peralta, H. Saad, S. Denetiere, J. Mahseredjian, and S. Nguéfeu, “Detailed and averaged models for a 401-level MMC-HVDC system,” in *2013 IEEE Power and Energy Society General Meeting (PES)*, 2013, pp. 1–1.
- [8] S. Rohner, J. Weber, and S. Bernet, “Continuous model of Modular Multilevel Converter with experimental verification,” in *2011 IEEE Energy Conversion Congress and Exposition (ECCE)*, 2011, pp. 4021–4028.
- [9] P. Delarue, F. Gruson, and X. Guillaud, “Energetic macroscopic representation and inversion based control of a modular multilevel converter,” in *2013 15th European Conference on Power Electronics and Applications (EPE)*, 2013, pp. 1–10.
- [10] U. N. Gnanarathna, A. M. Gole, and R. P. Jayasinghe, “Efficient Modeling of Modular Multilevel HVDC Converters (MMC) on Electromagnetic Transient Simulation Programs,” *IEEE Transactions on Power Delivery*, vol. 26, no. 1, pp. 316–324, Jan.2011.
- [11] N. Cherix, M. Vasiladiotis, and A. Rufer, “Functional modeling and Energetic Macroscopic Representation of Modular Multilevel Converters,” in *Power Electronics and Motion Control Conference (EPE/PEMC)*, 2012 15th International, 2012, pp.LS1a-1.3-1–LS1a-1.3-8.
- [12] Rapport technique CEI 61000-4-11 « Techniques d’essai et de mesure – Essais d’immunité aux creux de tension, coupures brèves et variations de tension » 1994, Commission Electrotechnique Internationale.
- [13] H.Saad “MODÉLISATION ET SIMULATION D’UNE LIAISON HVDC DE TYPE VSC-MMC,” Ph.D. Thesis, Ecole polytechnique de Montreal, Canada, 2015.
- [14] A. Boussayrol, B. Davat, B. de Fornel, B. François, J. P. Hautier, F. Meibody-Tabar, and M. Pietrzak-David, “Multimachine multiconverter system: application for electromechanical drives,” *Eur. Phys. J., Appl. Phys.*, vol. 10, no. 2, pp. 131–147, May 2000.
- [15] H. Cha, T. K. Vu and J. E. Kim, "Design and control of Proportional-Resonant controller based Photovoltaic power conditioning system," *2009 IEEE Energy Conversion Congress and Exposition*, San Jose, CA, 2009, pp.2198-2205. doi: 10.1109/ECCE.2009.5316374
- [16] P. L. Francos, S. S. Verdugo, H. F. Álvarez, S. Guynomarch and J. Loncle, "INELFE — Europe's first integrated onshore HVDC interconnection," *2012 IEEE Power and Energy Society General Meeting*, San Diego, CA, 2012, pp.1-8. doi: 10.1109/PESGM.2012.6344799